

Installing your new TrojanUVMax™ Power Supply

Step 1 - Confirm required components are present

You should have:

1 x Black Power Supply (Including Lamp Harness)



1 x Prepaid Return Shipping Label



Applicable only if you have received this package directly from VIQUA.

1 x Warranty Card



Applicable only if you have received this package directly from VIQUA.

NOTE: If any of these items are missing please contact **VIQUA** immediately at **1-800-265-5774**

Step 2 - Remove your existing Power Supply

1 You will need to first unplug the system from the wall outlet.



4 Using a screwdriver, undo the ground screw releasing both the ground (green) and strain relief (red) lines.



2 Remove the harness cap and lamp harness from the system.




5 Using your hands push the power supply upwards to remove it from its mounting bracket.



3 Remove the black lamp cover from the cord.



6 Unplug the power cord from the power supply.



continued on reverse side...

Step 3 - Install your new Power Supply

- ① Taking the power supply only, gently slide back onto the mounting bracket attached to the wall.




- ② Using a screwdriver, reattach the ground (green) and strain relief (red) to the UV chamber.



- ③ Snap the black lamp cover back over the cord.



- ④ Attach the lamp harness to the lamp being sure the 2 pronged jumpers are aligned to their contacts on the harness.



- ⑤ Take the original power cord and insert it first to the AC input of the power supply, then plug into wall outlet. Monitor the system to ensure both indicating light show solid green (this may take up to 5 mins).



NOTE: If LEDs do not go solid green, consult the troubleshooting section of your manual, or if you have any further questions regarding these instructions, please contact VIQUA at **1-800-265-5774**.

Step 4 - Return Defective Item

Note: Applicable only if you have received this package directly from VIQUA.
Return defective item within 7 days to avoid being charged.

- ① Place defective item into the box of your replacement power supply.
Note: the only item that should be returned to VIQUA is the black power supply.
- ② Remove original shipping label from box and replace with new prepaid shipping label included within this package.
- ③ Please call UPS at 1-800-742-5877 (Canada and US) and follow the voice prompts to arrange for a pick up.